DEKRA Testing and Certification (Suzhou) Co., Ltd.
No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China
TEL: +86-512-6251-5088 / FAX: +86-512-6251-5098

Test report Number:
2550700R.601

TEST REPORT
Electromagnetic Compatibility (EMC)

Identification of item tested	RobStride 06
Trademark	robstride
Model and /or type reference	RSQDD-PG-11-36-01A
Features	N/A
Derived model(s)	N/A
Applicant´s name / address	RobStride Dynamics Co., Ltd Room 803, Building 49, No. 3 Yard, Jinhai 5th Road, Economic and Technological Development Zone, Beijing, China
Test method requested, standard	EN IEC 61000-6-1:2019 EN IEC 61000-6-3:2021
Verdict Summary	IN COMPLIANCE
Tested by (name / position & signature)	Dachuang Zou/Project Engineer Dachuang Zou
Approved by (name / position & signature)	Star Wang/Manager Star Wang 2025-08-22 13:35:29
Date of issue	August 22, 2025
Report template No.	Template_EN_IEC 61000-6-1-2-3-4-EMC-V2.0

INDEX

Page No.

Competences and Guarantees 4
General conditions 4
Uncertainty 4
Environmental conditions 4
Possible test case verdicts 5
Definition of symbols used in this test report 5
Abbreviations 5
Document History 6
Remarks and Comments 6
1 General Information 7
1.1 General Description of the Item(s) 7
1.2 The environment(s) in which the EUT is intended to be used 8
1.3 Test location and date 8
2 Description of Test Setup 9
2.1 Operating mode(s) used for tests 9
2.2 Port(s) of the EUT 9
2.3 Support / Auxiliary equipment / unit / software for the EUT 9
2.4 Test Configuration / Block diagram used for tests 10
3 Verdict summary section 11
3.1 Standards 11
3.2 Deviation(s) from the Standard(s) / Test Specification(s) 12
3.3 Overview of results 13
3.4 Test Matrix 14
4 Emission Test Results 15
4.1 Conducted disturbance voltage at AC mains port(s) 15
4.2 Discontinuous disturbance (clicks) at AC mains port(s) 17
4.3 Conducted disturbance voltage at DC power port(s) 19
4.4 Conducted disturbance at Wired network port or other wired port(s) 22
4.5 Radiated electromagnetic disturbances (30 – 1000 MHz) 25
4.6 Radiated electromagnetic disturbances (above 1 GHz) 28
4.7 Harmonic current emissions 30

4.8 Voltage changes, voltage fluctuations and flicker 33
5 Immunity Test Results 35
5.1 Performance (Compliance) criteria 35
5.1.1 Performance criteria related to immunity tests 35
5.1.2 Manufacturer defined performance criteria 35
5.2 Monitored – Checked Functions / Parameters 36
5.3 Electrostatic discharge immunity 37
5.4 Radio-frequency electromagnetic fields immunity 41
5.5 Electrical Fast Transients immunity 42
5.6 Surge transient immunity 43
5.7 Injected currents (RF common mode) immunity 44
5.8 Power frequency magnetic field immunity 45
5.9 Power supply interruptions and dips immunity 46
6 Identification of the Equipment Under Test 47
7 Annex 1 - Measurement Uncertainties 49
8 Annex 2 - Test Photos 50
9 Annex 3 - EUT Photos 53

COMPETENCES AND GUARANTEES

DEKRA is a testing laboratory competent to carry out the tests described in this report.

In order to assure the traceability to other national and international laboratories, DEKRA has a calibration and maintenance program for its measurement equipment.

DEKRA guarantees the reliability of the data presented in this report, which is the result of the measurements and the tests performed to the item under test on the date and under the conditions stated in the report and it is based on the knowledge and technical facilities available at DEKRA at the time of performance of the test.

DEKRA is liable to the client for the maintenance of the confidentiality of all information related to the item under test and the results of the test.

The results presented in this Test Report apply only to the particular item under test established in this document.

IMPORTANT: No parts of this report may be reproduced or quoted out of context, in any form or by any means, except in full, without the previous written permission of DEKRA.

GENERAL CONDITIONS

1. This report is only referred to the item that has undergone the test.
2. This report does not constitute or imply on its own an approval of the product by the Certification Bodies or Competent Authorities.
3. This document is only valid if complete; no partial reproduction can be made without previous written permission of DEKRA.
4. This test report cannot be used partially or in full for publicity and/or promotional purposes without previous written permission of DEKRA.

UNCERTAINTY

For all measurements where guidance for the calculation of the instrumentation uncertainty of a measurement is specified in EN 55016-4-2 (CISPR 16-4-2), EN/IEC 61000-4 series or a product standard, the measurement instrumentation uncertainty has been calculated and applied in accordance with these standards.

Uncertainties have been calculated according to the DEKRA internal document PROD-P-EMC-M22. The reported expanded uncertainties are based on a standard uncertainty multiplied by a coverage factor of k=2, providing a level of confidence of approximately 95%. Refer to the Annex 1 for furter information.

ENVIRONMENTAL CONDITIONS

The climatic conditions during the tests are within the limits specified by the manufacturer for the operation of the EUT and the test equipment. The climatic conditions during the tests were within the following limits:

Ambient temperature	15 °C – 35 °C
Relative Humidity air	25 % - 75 %;30 % - 60 %(ESD)
Atmospheric pressure	86 kPa – 106 kPa

If explicitly required in the basic standard or applied product / product family standard the climatic values are recorded and documented separately in this test report.

POSSIBLE TEST CASE VERDICTS

Test case does not apply to test object	N/A
Test object does meet requirement	P (Pass) / PASS
Test object does not meet requirement	F (Fail) / FAIL
Not measured	N/M

DEFINITION OF SYMBOLS USED IN THIS TEST REPORT

☒ Indicates that the listed condition, standard or equipment is applicable for this report/test/EUT.				
☐ Indicates that the listed condition, standard or equipment is not applicable for this report/test/EUT.				
Decimal separator used in this report	☐	Comma (,)	☒	Point (.)

ABBREVIATIONS

For the purposes of the present document, the following abbreviations apply:

EUT	:	Equipment Under Test
QP	:	Quasi-Peak
CAV	:	CISPR Average
AV	:	Average
CDN	:	Coupling Decoupling Network
SAC	:	Semi-Anechoic Chamber
OATS	:	Open Area Test Site
BW	:	Bandwidth
AM	:	Amplitude Modulation
PM	:	Pulse Modulation
HCP	:	Horizontal Coupling Plane
VCP	:	Vertical Coupling Plane
U_N	:	Nominal voltage
Tx	:	Transmitter
Rx	:	Receiver
N/A	:	Not Applicable
N/M	:	Not Measured

DOCUMENT HISTORY

Report Number	Date	Description
2550700R.601	August 22, 2025	First release

REMARKS AND COMMENTS

1.The equipment under test (EUT) does meet the essential requirements of the stated standard(s)/test(s).

2.These test results on a sample of the device are for the purpose of demonstrating Compliance with EN IEC 61000-6-1:2019, EN IEC 61000-6-3:2021.

3. The test results presented in this report relate only to the object tested.
4. This report will not be used for social proof function in China market.
5. The measurement result is considered in conformance with the requirement if it is within the prescribed limit, It is not necessary to account the uncertainty associated with the measurement result.
6. This report must not be used to claim product endorsement by TAF or any agency of the government.
7. This report shall not be reproduced, except in full, without the written approval of DEKRA Testing and Certification (Suzhou) Co., Ltd.

1 GENERAL INFORMATION

1.1 General Description of the Item(s)

Description of the item ..... :	RobStride 06
Model / Type number ..... :	RSQDD-PG-11-36-01A
Serial number ..... :	N/A
Trademark ..... :	robstride
Manufacturer ..... :	RobStride Dynamics Co., Ltd
Address……:	Room 803, Building 49, No. 3 Yard, Jinhai 5th Road, Economic and Technological Development Zone, Beijing, China

Note 1: The EUT information is from customer declaration.

			Reference poles				
Rated power supply ..... :	Voltage and Frequency		L1	L2	L3	N	PE
	☐	AC: 220 – 240 V, 50/60 Hz	☐	☐	☐	☐	☐
	☐	AC: 100 – 240 V, 50/60 Hz	☐	☐	☐	☐	☐
	☒	DC: 48 Vdc					
Rated Power ..... :	Not provided						
Clock frequencies :	Not provided						
Other parameters..... :	Not provided						
Software version ..... :	0.5.0.1						
Hardware version..... :	0.5.0.1						
Dimensions in cm (L x W x H) .... :	Not provided						
Mounting position..... :	☒	Table top equipment					
	☐	Wall/Ceiling mounted equipment					
	☐	Floor standing equipment					
	☐	Hand-held equipment					
	☐	Other:					

Intended use of the Equipment Under Test (EUT)
The EUT is a commercial and light-industrial equipment environment.

No	Module/parts of test item			Type	Manufacturer
---	---			---	---
No	Documents as provided by the applicant - Description			File name	Issue date
---	---			---	---
Modifications to the test item during testing ..... :	☒	N/A	☐	Supplemental information:	

Copy of marking plate:
N/A

1.2 The environment(s) in which the EUT is intended to be used

The equipment under test (EUT) is intended to be used in the following environment(s):

☐	Residential (domestic) environment.
☒	Commercial and light-industrial environment
☐	Industrial environment

1.3 Test location and date

Test Location	No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China
Date (receive sample)	July 04, 2025
Date (start)	July 04, 2025
Date (finish)	July 12, 2025

2 DESCRIPTION OF TEST SETUP

2.1 Operating mode(s) used for tests

During the tests the following operating mode(s) has(have) been used.

Operating mode	Operating mode description	Used for testing	
		Emission	Immunity
1	Normal operation (The working parameters were set through the test software, and the motor began to operate)	☒	☒
Supplemental information:			

2.2 Port(s) of the EUT

Port name and description	Connected to / Termination	Cable		
		Length used during test [m]	Attached during test	Shielded
USB-Type c Port	Notebook	0.8	☒	☐
CAN Cable Port	PCB CAN	0.1	☒	☐
Supplemental information:				

2.3 Support / Auxiliary equipment / unit / software for the EUT

The EUT has been tested with the following auxiliary equipment / unit / software:


Auxiliary equipment / unit / software	Type / Version	Manufacturer	Supplied by
Notebook	X250	Lenovo	DEKRA
PCB CAN	N/A	N/A	DEKRA
Supplemental information:			

2.4 Test Configuration / Block diagram used for tests

The following test setup / configuration / block diagram has been used during the tests:

Test Item		EMI / EMS			
Product		Manufacturer	Model No.	Serial No.	Power Cord
1	Notebook	Lenovo	X250	N/A	Power by Adapter
2	PCB CAN	N/A	N/A	N/A	Power by Notebook

Test Configuration / Block diagram



Signal Cable Type		Signal cable Description
A	USB-Type c Cable	Non-Shielded, 0.8 m
B	CAN Cable	Non-Shielded, 0.1 m

3 VERDICT SUMMARY SECTION

This chapter presents an overview of standards and results. Refer to the next chapters for details of measured test results and applied test levels.

3.1 Standards

Standard	Year	Description
EN IEC 61000-6-3	2021	Electromagnetic compatibility (EMC) - Part 6-3: Generic standards - Emission standard for equipment in residential environments
EN IEC 61000-6-4	2019	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments
EN IEC 61000-6-1	2019	Electromagnetic compatibility (EMC) - Part 6-1: Generic standards - Immunity standard for residential, commercial and light-industrial environments
EN IEC 61000-6-2	2019	Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity standard for industrial environments
CISPR 16-2-1 +A1	2014 2017	Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements
CISPR 16-2-3	2016	Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-3: Methods of measurement of disturbances and immunity – Radiated disturbance measurements
CISPR 32	2015	Electromagnetic compatibility of multimedia equipment – Emission requirements
CISPR 14-1	2016	Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission
EN IEC 61000-3-2 +A1	2018 2021	Limits for harmonic current emissions (equipment input current ≤ 16 A per phase).
EN 61000-3-3 +A1	2013 2019	Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection.
EN 61000-3-12	2011	Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase.
EN IEC 61000-3-11	2019	Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection.
IEC 61000-4-2	2008	Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test
IEC 61000-4-3	2020	Electromagnetic compatibility (EMC) – Part 4-3 : Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test
IEC 61000-4-4	2012	Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test
IEC 61000-4-5 +A1	2014 2017	Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques - Surge immunity test
IEC 61000-4-6	2013	Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields
IEC 61000-4-8	2009	Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test
IEC 61000-4-11	2020	Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests

IEC 61000-4-34 +A1	2005 2009	Electromagnetic compatibility (EMC) – Part 4-34: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase
EN IEC 55014-1	2021	Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission.

3.2 Deviation(s) from the Standard(s) / Test Specification(s)

No deviation.

3.3 Overview of results

EMISSION TESTS –☒EN IEC 61000-6-3, ☐EN IEC 61000-6-4			
Requirement – Test case	**Basic standard(s)**	**Verdict**	**Remark**
Conducted disturbance voltage at AC power port(s)	CISPR 16-2-1	N/A	See 1)
Conducted disturbance voltage at DC power port(s)	CISPR 16-2-1	N/A	See 2)
Conducted disturbance voltage at Telecommunications / network port(s)	CISPR 32, CISPR 16-2-1	N/A	See 4)
Radiated electromagnetic disturbances (30 MHz to 1000 MHz)	CISPR 16-2-3	Pass	---
Radiated electromagnetic disturbances (above 1 GHz)	CISPR 16-2-3	N/A	See 5)
Discontinuous disturbance (clicks)	CISPR 14-1	N/A	See 3)
Supplementary information: 1) The EUT does not have an AC mains power input / output port. 2) The test is not applicable to DC power input / output ports connected to cable(s) ⩽ 3 m. 3) Exemptions from click measurements applicable (see CISPR 14-1:2016 clause 5.4.3). 4) The EUT does not contain the interface defined below: a. wired network ports b. optical fibre ports with metallic shield or tension members c. broadcast receiver tuner ports d. antenna ports 5) The highest frequency of the EUT is less than 108 MHz.			

EMISSION TESTS –☐EN IEC 61000-3-2, ☐EN 61000-3-12, ☐EN 61000-3-3, ☐EN IEC 61000-3-11			
Requirement – Test case	**Basic standard(s)**	**Verdict**	**Remark**
Harmonic current emissions	EN IEC 61000-3-2 or EN 61000-3-12	N/A	See 1)
Voltage changes, voltage fluctuations and flicker	EN 61000-3-3 or EN IEC 61000-3-11	N/A	See 1)
Supplementary information: 1) The EUT does not have an AC mains power input / output port.			

IMMUNITY TESTS –☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2			
Requirement – Test case	**Basic standard(s)**	**Verdict**	**Remark**
Electrostatic discharge	EN 61000-4-2	Pass	---
Radio-frequency electromagnetic fields	EN 61000-4-3	Pass	---
Fast transients	EN 61000-4-4	N/A	See 1)
Surge transient	EN 61000-4-5	N/A	See 1)
Injected currents (radio-frequency common mode)	EN 61000-4-6	N/A	See 1)
Power frequency magnetic fields	EN 61000-4-8	Pass	---
Voltage dips and short interruptions	☐IEC 61000-4-11 ☐IEC 61000-4-34	N/A	See 2)
Supplementary information: 1) The test is not applicable to DC power input / output ports connected to cable(s) ⩽ 3 m. 2) The EUT does not have an AC mains power input / output port.			

3.4 Test Matrix

EMISSION TESTS	Model / Type
	Mode 1
Conducted disturbance voltage at AC power port(s) (150 kHz – 30 MHz)	☐
Conducted disturbance voltage at DC power port(s) (150 kHz – 30 MHz)	☐
Conducted disturbance voltage at telecommunications/ network port (150 kHz – 30 MHz)	☐
Radiated electromagnetic disturbances (30 MHz to 1000 MHz)	☒
Radiated electromagnetic disturbances (above 1 GHz)	☐
Discontinuous disturbance (clicks)	☐
Harmonic current emissions	☐
Voltage changes, voltage fluctuations and flicker	☐
Supplementary Information:	

IMMUNITY TESTS	Model / Type
	Mode 1
Electrostatic discharge	☒
Radio-frequency electromagnetic fields	☒
Fast transients	☐
Surges	☐
Injected currents (radio-frequency common mode)	☐
Power frequency magnetic field immunity	☒
Voltage dips and short interruptions	☐
Supplementary Information:	

4 EMISSION TEST RESULTS

4.1 **Conducted disturbance voltage at AC mains port(s)**	**VERDICT: N/A**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4**
Basic standard(s)	CISPR 16-2-1

Limits for EN IEC 61000-6-3

Frequency range [MHz]	Limit: QP [dB(μV)[1)]]	Limit: AV [dB(μV)[1)]]	IF BW	Detector(s)
0,15 – 0,50	66 – 56 [2)]	56 – 46 [2)]	9 kHz	QP, CAV
0,50 – 5,0	56	46	9 kHz	QP, CAV
5,0 – 30	60	50	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.
[2)] The limit decreases linearly with the logarithm of the frequency.

Limits for EN IEC 61000-6-4

Frequency range [MHz]	Limit: QP [dB(μV)[1)]]	Limit: AV [dB(μV)[1)]]	IF BW	Detector(s)
0,15 – 0,50	79	66	9 kHz	QP, CAV
0,50 – 30	73	60	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.

Performed measurements

Port under test		Terminal							
☐	AC input port	☐	N	☐	L1	☐	L2	☐	L3
☐	Other:	☐	N	☐	L1	☐	L2	☐	L3

Voltage – Mains [V]	---			
Frequency – Mains [Hz]	---			
Test method applied	☐	Artificial mains network		
	☐	Voltage probe		
Test setup	☐	Table top	☐	Artificial hand applied
	☐	Floor standing	☐	Other:

Operating mode(s) used	---			
Remark	---			

See next page.

Measurement data	Port under test	---
Operating mode / voltage / frequency used during the test		---
The EUT does not have an AC mains power input / output port.		
Remark	---	

4.2 **Discontinuous disturbance (clicks) at AC mains port(s)**	**VERDICT: N/A**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4**	
Basic standard(s)	CISPR 14-1	
Exlusions	☐	Test item only causes single switching events (CISPR 14-1 5.4.3.2)
	☐	Combination of disturbances in a time frame less than 600 ms (CISPR 14-1 5.4.3.3)
	☐	Instantaneous switching (CISPR 14-1 5.4.3.4)
	☐	Separation less than 200 ms (CISPR 14-1 5.4.3.5)
	☐	Thermostatically controlled three-phase switches (CISPR 14-1 5.4.3.6)
	☐	Superposition of clicks with continuous disturbance (CISPR 14-1 5.4.3.7)
	☐	Other:

Limits

Frequency [MHz]	Limit: QP [dB(μV)]	IF BW	Detector
0,15	66	9 kHz	QP
0,50	56	9 kHz	QP
1,40	56	9 kHz	QP
30,0	60	9 kHz	QP

Performed measurements

Voltage – Mains [V]	---			
Frequency – Mains [Hz]	---			
Test method applied	☐	Artificial mains network:V-AN		
	☐	Voltage probe		
Test setup	☐	Table top	☐	Floor standing
	☐	Other:		

Operating mode(s) used	---			
Remark	---			

See next page.

Measurement data	Port under test	---
Operating mode / voltage / frequency used during the test		---

Exemptions from click measurements applicable (see CISPR 14-1:2016 clause 5.4.3).

Remark	---

4.3 **Conducted disturbance voltage at DC power port(s)**	**VERDICT: N/A**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4,** ☐**EN IEC 55014-1**
Basic standard(s)	CISPR 16-2-1

The applicability to DC port(s)

No.	Description of DC power source connection[d]	Intended cable connection [d]	Specifics and additional requirements
1	Distribution network [a]	All types	---
2	Remote battery	Is longer than 3 m	Applicable in case of remote battery connected to only one piece of equipment
3	External AC/DC converter or battery charger	Is longer than 3 m [b]	
4	External DC/DC converter or battery charger	Is longer than 3 m [b]	The DC input port of the charger/converter [c] shall also be tested.
5	All other DC power sources not defined above	Is longer than 3 m	---

a. DC distribution networks include:
- those enclosed within a car, truck, train or similar vehicle (independent of length),
- those with an overall length greater than 3 m.

b. The length of the cable between the DC port and the convertor or charger.
c. Where possible, use a device specified in the user instructions, else use a typical device capable of developing the necessary DC voltage/current.
d. Based upon the intended use of the equipment as defined in the user instructions.

Limits for EN IEC 61000-6-3

Limits: V-AN

Frequency range [MHz]	Limit: QP [dB(μV)[1)]]	Limit: AV [dB(μV) [1)]]	IF BW	Detector(s)
0,15 - 0,50	79	66	9 kHz	QP, CAV
0,50 - 30	73	60	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.

Limits: △-AN

Frequency range [MHz]	Limit: QP [dB(μV)[1)]]	Limit: AV [dB(μV) [1)]]	IF BW	Detector(s)
0,15 - 0,50	84-74 [2)]	74-64 [2)]	9 kHz	QP, CAV
0,50 - 30	74	64	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.
[2)] The limit decreases linearly with the logarithm of the frequency.

The start frequency of test defined in table"The applicability to DC port(s)" No. 2 to 5 for EN IEC 61000-6-3

Cable length *l* m	Start frequency MHz f_{start}
3< *l* <30	f_{start} = 60 / *l*
l ⩾ 30	f_{start} = 0,15

Cable length *l* m	Start frequency MHz f_{start}
Not defined	
l = maximum supported cable length intended to be connected to the DC power port Measurement shall be performed across the range from f_{start} to 30 MHz.	

According to the cable length of DC power port

f_{start} =	☐ MHz	☒0.15MHz

Limits for EN IEC 61000-6-4

Frequency range [MHz]	Limit: QP [dB(µV)[1)]]	Limit: AV [dB(µV) [1)]]	IF BW	Detector(s)
0,15 - 0,50	89	76	9 kHz	QP, CAV
0,50 - 30	83	70	9 kHz	QP, CAV
[1)] At the transition frequency, the lower limit applies.				

Performed measurements

Port under test		Terminal			
☐	DC power input port	☐	Positive (+)	☐	Negative (-)
☐	Other:	☐	Positive (+)	☐	Negative (-)

Voltage – Input [VDC]	---			
Voltage – Output [V_{DC}]	---			
Test method applied	☐	Artificial mains network:V-AN		
	☐	Voltage probe		
Test setup	☐	Table top	☐	Artificial hand applied
	☐	Floor standing	☐	Other:

Operating mode(s) used	---			
Remark	---			

See next page.

Measurement data	Port under test	---
Operating mode / voltage		---
The test is not applicable to DC power input / output ports connected to cable(s) ≤ 3 m.		
Remark		

4.4	**Conducted disturbance at Wired network port or other wired port(s)**	**VERDICT: N/A**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4**
Basic standard(s)	CISPR 32, CISPR 16-2-1

Limits for EN IEC 61000-6-3

Applicable to
1. wired network ports
2. optical fibre ports with metallic shield or tension menbers
3. broadcast receiver tuner ports
4. antenna ports

Frequency range [MHz]	Limit: QP [dB(µV)[1)]]	Limit: AV [dB(µV) [1)]]	Limit: QP [dB(µA)[1)]]	Limit: AV [dB(µA) [1)]]	IF BW	Detector(s)
0,15 - 0,50	84 – 74 [2)]	74 – 64 [2)]	40 – 30 [2)]	30 – 20 [2)]	9 kHz	QP, CAV
0,50 - 30	74	64	30	20	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.
[2)] The limit decreases linearly with the logarithm of the frequency.

Limits for EN IEC 61000-6-4

Applicable to
1. wired network ports
2. optical fibre ports with metallic shield or tension menbers
3. antenna ports

Frequency range [MHz]	Limit: QP [dB(µV)[1)]]	Limit: AV [dB(µV) [1)]]	Limit: QP [dB(µA)[1)]]	Limit: AV [dB(µA) [1)]]	IF BW	Detector(s)
0,15 - 0,50	97 – 87 [2)]	84 – 74 [2)]	53 – 43 [2)]	40 – 30 [2)]	9 kHz	QP, CAV
0,50 - 30	87	74	43	30	9 kHz	QP, CAV

[1)] At the transition frequency, the lower limit applies.
[2)] The limit decreases linearly with the logarithm of the frequency.

Performed measurements

Port under test			
☐	LAN	☐	Other:
☐	Other: Signal port	☐	Other:

Voltage – Mains [V]	---
Frequency – Mains [Hz]	---

Test method applied	☐	ISN – Impedance Stabilisation Network
	☐	Voltage probe
	☐	Current probe
	☐	Artificial mains network

	☐	Other:		
Test setup	☐	Table top	☐	Artificial hand applied
	☐	Floor standing	☐	Other:

Operating mode(s) used	---			
Remark	---			

See next page.

Measurement data	Port under test	---
Operating mode / voltage / frequency used during the test		---

The EUT does not contain the interface defined below:

a. wired network ports

b. optical fibre ports with metallic shield or tension members

c. broadcast receiver tuner ports

d. antenna ports

Remark	---

4.5	**Radiated electromagnetic disturbances (30 – 1000 MHz)**	**VERDICT: PASS**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4,** ☐**EN IEC 55014-1**
Basic standard(s)	CISPR 16-2-3
Test method	Antenna method according to CISPR 16-2-3 standard.

Limits for EN IEC 61000-6-3

Frequency	Limit: QP [dB(μV/m)[1)]]		IF BW	Detector
[MHz]	@3 m.	@10 m.		
30 - 230	40	30	120 kHz	QP
230 - 1000	47	37	120 kHz	QP
[1)] At the transition frequency, the lower limit applies.				

Limits for EN IEC 61000-6-4

Frequency	Limit: QP [dB(μV/m)[1)]]		IF BW	Detector
[MHz]	@3 m.	@10 m.		
30 - 230	50	40	120 kHz	QP
230 - 1000	57	47	120 kHz	QP
[1)] At the transition frequency, the lower limit applies.				


Performed measurements

Port under test	Enclosure Port	
Voltage – Mains [V]	48 Vdc	
Frequency – Mains [Hz]	---	
Test method applied	☒	OATS or SAC with measurement distance [m]: 3 m.
	☐	OATS or SAC with measurement distance [m]: 10 m.
Test setup	☒	Equipment on a table of 80 cm height
	☐	Equipment on the floor (insulated from ground plane)
	☐	Other:
	Refer to the Annex 2 for test setup photo(s).	
Operating mode(s) used	Mode 1	
Remark	---	

See next page.

Measurement data	☒	Horizontal	☐	Vertical
Operating mode / voltage / frequency used during the test		Mode 1/ 48 Vdc		

Engineer: JIM	
Site: AC2	Time: 2025/07/04
Limit: EN 61000-6-3_RE (3m)_Class B	Margin: 0
Probe: CBL6112B_2933(30-1000MHz)-2024	Polarity: Horizontal
EUT: RobStride 06	Power: DC 48V
Note: Mode 1	



No	Mark	Frequency (MHz)	Measure Level (dBuV/m)	Reading Level (dBuV)	Over Limit (dB)	Limit (dBuV/m)	Probe (dB/m)	Cable (dB)	Amp (dB)	Ant Pos (cm)	Table Pos (deg)	Type
1	*	31.226	31.904	7.400	-8.096	40.000	18.107	6.398	0.000	324	322	QP
2		56.358	27.413	14.100	-12.587	40.000	6.669	6.644	0.000	315	108	QP
3		59.586	29.503	16.500	-10.497	40.000	6.336	6.667	0.000	396	272	QP
4		240.115	31.096	12.100	-15.904	47.000	11.539	7.456	0.000	166	30	QP
5		480.216	34.707	9.500	-12.293	47.000	17.041	8.166	0.000	218	97	QP
6		930.025	31.469	2.100	-15.531	47.000	20.180	9.189	0.000	158	178	QP


Note:

1. " * ", means this data is the worst emission level.
2. Measurement Level = Reading Level + Factor(Probe+Cable-Amp).

Remark	

Measurement data	☐	Horizontal	☒	Vertical
Operating mode / voltage / frequency used during the test		Mode 1/ 48 Vdc		

Engineer: JIM	
Site: AC2	Time: 2025/07/04
Limit: EN 61000-6-3_RE (3m)_Class B	Margin: 0
Probe: CBL6112B_2933(30-1000MHz)-2024	Polarity: Vertical
EUT: RobStride 06	Power: DC 48V
Note: Mode 1	



No	Mark	Frequency (MHz)	Measure Level (dBuV/m)	Reading Level (dBuV)	Over Limit (dB)	Limit (dBuV/m)	Probe (dB/m)	Cable (dB)	Amp (dB)	Ant Pos (cm)	Table Pos (deg)	Type
1		31.264	28.988	4.500	-11.012	40.000	18.090	6.398	0.000	297	190	QP
2	*	36.253	29.459	7.400	-10.541	40.000	15.631	6.428	0.000	270	238	QP
3		38.265	28.077	7.100	-11.923	40.000	14.538	6.440	0.000	324	14	QP
4		51.243	27.066	12.400	-12.934	40.000	8.057	6.608	0.000	122	15	QP
5		59.885	27.075	14.100	-12.925	40.000	6.306	6.669	0.000	104	339	QP
6		143.856	27.798	9.500	-12.202	40.000	11.219	7.079	0.000	146	254	QP

Note:

1. " * ", means this data is the worst emission level.
2. Measurement Level = Reading Level + Factor(Probe+Cable-Amp).

Remark	

4.6 **Radiated electromagnetic disturbances (above 1 GHz)**	**VERDICT: N/A**

Standard	☒**EN IEC 61000-6-3,** ☐**EN IEC 61000-6-4,** ☐**EN IEC 55014-1**	
Basic standard(s)	CISPR 16-2-3	
Test method	Antenna method according to CISPR 16-2-3 standard.	
Required highest frequency for radiated measurement		
Highest internal frequency [f_x]		Highest measured frequency
☒	$f_x \leq 108$ MHz	1 GHz
☐	108 MHz < $f_x \leq 500$ MHz	2 GHz
☐	500 MHz < $f_x \leq 1$ GHz	5 GHz
☐	$f_x \geq 1$ GHz	5x f_x or up to 6 GHz
☐	unknown	6GHz

Limits for EN IEC 61000-6-3

Frequency [GHz]	Limit: PK@3m.[dB(µV/m)[1)]]	Limit: AV@3m.[dB(µV/m)[1)]]	IF BW	Detector
1 - 3	70	50	1 MHz	PK, CAV
3 - 6	74	54	1 MHz	PK, CAV
[1)] At the transition frequency, the lower limit applies.				

Limits for EN IEC 61000-6-4

Frequency [GHz]	Limit: PK@3m.[dB(µV/m)[1)]]	Limit: AV@3m.[dB(µV/m)[1)]]	IF BW	Detector
1 - 3	76	56	1 MHz	PK, CAV
3 - 6	80	60	1 MHz	PK, CAV
[1)] At the transition frequency, the lower limit applies.				

Performed measurements

Port under test	Enclosure Port	
Voltage – Mains [V]	---	
Frequency – Mains [Hz]	---	
Test method applied	☐	Absorber-lined OATS or SAC with measurement distance [m]: 3 m.
	☐	Absorber-lined OATS or SAC with measurement distance [m]: 1 m.
Test setup	☐	Equipment on a table of 80 cm height
	☐	Equipment on the floor (insulated from ground plane)
	☐	Other:

Operating mode(s) used	---	
Remark	---	

See next page.

Measurement data	☐	**Horizontal**	☐	**Vertical**
Operating mode / voltage / frequency used during the test		---		

The highest frequency of the EUT is less than 108 MHz.

Remark	

4.7 **Harmonic current emissions**	**VERDICT: N/A**

Standard	☐EN IEC 61000-3-2, ☐EN 61000-3-3, ☐EN 61000-3-12	
Basic standard	EN IEC 61000-3-2,EN 61000-3-12	
Exlusions (For these categories of equipment, limits are not specified in the EN 61000-3-2 standard)	☐	lighting equipment with a rated power less than but not equal to 5 W
	☐	equipment with a rated power of 75 W or less, other than lighting equipment
	☐	professional equipment with a total rated power greater than 1 kW
	☐	symmetrically controlled heating elements with a rated power less than or equal to 200 W
	☐	independent phase control dimmers - with a rated power less than or equal to 1 kW when operating incandescent lamps - with a rated power less than or equal to 200 W for trailing edge dimmers, and universal phase control dimmers with the default mode set to trailing edge, when operating lighting equipment other than incandescent lamps - with a rated power less than or equal to 100 W for leading edge dimmers, and universal phase control dimmers without default mode set to trailing edge, when operating lighting equipment other than incandescent lamps

Classification（I_{input}≤ 16A）				
☐	Class A	All apparatus not classified as Class B, C or D		
☐	Class B	Portable tools, arc welding equipment which is not professional equipment		
☐	Class C	☐	Lighting equipment with rated power > 25 W (Table 2)	
		☐	Lighting equipment with rated power≥ 5 W and ≤ 25 W (First requirement, Table 3 column 2)	
			☐	Table 3, column 2 (Power related limits)
			☐	3rd harmonic ⩽ 86 %, 5th harmonic ⩽ 61 % and waveform conditions
			☐	THD ⩽ 70 %, Harmonics: 3rd ⩽35 %, 5th ⩽ 25 %, 7th ⩽ 30 %, 9th and 11th ⩽ 20 %, 2nd ⩽ 5 %
			☐	Other:
☐	Class D	Equipment having a specified power according to EN IEC 61000-3-2 6.3.2, less than or equal to 600 W, of the following types: - personal computers and personal computer monitors - television receivers - refrigerators and freezers having one or more variable-speed drives to control compressor - motor(s)		

Classification（16A≤ I_{input}<75A）		
☐	Table 2	other than balanced three-phase equipment
☐	Table 3	balanced three-phase equipment
☐	Table 4	balanced three-phase equipment under specified conditions(a,b,c)
☐	Table 5	balanced three-phase equipment under specified conditions(d,e,f)

Performed measurements

Port under test	---					
Voltage – Mains [V]	---					
Frequency – Mains [Hz]	---					
Observation peroid	☐	6.5 min.	☐	2.5 min.	☐	Other:
Version of measurement instrument standard used EN / IEC61000-4-7 (Cl. 7)	☐	EN 61000-4-7:2002 + AM1:2009 (IEC 61000-4-7:2002+AM1:2008)				
	☐	EN 61000-4-7:1991				
Control principle used in the EUT	☐	Comply with the requirements of the Clause 6.2 (EN / IEC 61000-3-2).				
	☐	Comply with the requirements of the Clause 5.1 (EN / IEC 61000-3-12).				
	☐	Not comply with the requirements of the Clause 6.2 (EN / IEC 61000-3-2).				
	☐	Not comply with the requirements of the Clause 5.1 (EN / IEC 61000-3-12).				
Operating mode(s) used	---					
Remark	---					

See next page.

Measurement data	Port under test	---
Operating mode / voltage / frequency used during the test		---

The EUT does not have an AC mains power input / output port.

Remark	

4.8 Voltage changes, voltage fluctuations and flicker — VERDICT: N/A

Standard	☐EN IEC 61000-3-2, ☐ EN 61000-3-3, ☐EN IEC 61000-3-11
Basic standard	EN 61000-3-3, EN IEC 61000-3-11

apply for	☐	EN 61000-3-3		
	☐	EN IEC 61000-3-11	☐	Z_{test} = 0,25 + j 0,25 Ω
			☐	Z_{test} = 0,15 + j 0,15 Ω for line, 0,1 + j 0,1 Ω for neutral
			☐	Z_{test} =
Supplemental information:				

Limits

P_{ST} (Short term flicker)	☐	≤ 1	☐	Not Applicable
P_{LT} (Long term flicker)	☐	≤ 0,65	☐	Not Applicable
d_C (Relative Voltage change)	☐	≤ 3,3%	☐	Not Applicable
T_{max} (Maximum time duration)	☐	≤ 500ms	☐	Not Applicable
d_{MAX} (Max. voltage change)	☐	≤ 4%	☐	6%
	☐	7%	☐	Not Applicable
Supplemental information:				

Performed measurements

Reason for not performing the measurement(s)	☐	Tests are not necessary because the EUT is unlikely to produce significant voltage fluctuations or flicker (clause 6.1 of EN 61000-3-3).				
Port under test	---					
Voltage – Mains [V]	---					
Frequency – Mains [Hz]	---					
Test method	☐	Flickermeter according EN / IEC 61000-4-15:2011				
	☐	Simulation (Clause 4.2.3 of EN / IEC 61000-3-3)				
	☐	Analytical method (Clause 4.2.4 of EN / IEC 61000-3-3)				
	☐	Use of P_{st} = 1 curve (Clause 4.2.5 of EN / IEC 61000-3-3)				
Observation peroid	☐	10 min.	☐	120 min.	☐	Other:
	☐	24 times switching according to Annex B of the standard				
Operating mode(s) used	---					
Remark	---					

See next page.

Measurement data	Port under test	---
Operating mode / voltage / frequency used during the test		---

The EUT does not have an AC mains power input / output port.

Remark	

5 IMMUNITY TEST RESULTS

5.1 Performance (Compliance) criteria

[Source: EN IEC 61000-6-1&EN IEC 61000-6-2]

Performance criterion A: The EUT shall continue to operate as intended during and after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the EUT is used as intended. If the performance level is not specified by the manufacturer, this may be derived from the product description and documentation and what the user may reasonably expect from the equipment if used as intended.

Performance criterion B: The EUT shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the EUT is used as intended. The performance level may be replaced by a permissible loss of performance. However, during the test degradation of performance is allowed but no change of actual operating state or stored data is allowed. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, either of these may be derived from the product description and documentation and what the user may reasonably expect from the equipment if used as intended.

Performance criterion C: Temporary loss of function is allowed during the test, provided the function is self-recoverable or can be restored by the operation of the controls.

5.1.1 Performance criteria related to immunity tests

Immunity test	Performance criteria
Electrostatic discharge	B
Radio-frequency electromagnetic fields	A
Fast transients	B
Surge transient	B
Injected currents (radio-frequency common mode)	A
Power frequency magnetic field immunity	A
Voltage dips and short interruptions	B, C

5.1.2 Manufacturer defined performance criteria

Not provided.

5.2 Monitored – Checked Functions / Parameters

During the immunity tests the following functions of the EUT has/have been monitored/checked.

☒	Motor speed	☐	Display data
☐	Switching	☐	Data storage
☐	Standby mode	☐	Sensor functions
☐	Temperature	☐	Audible signals
☐	Power consumption	☒	Others: Connect the notebook computer to monitor the motor speed parameters through the software
☐	AC mains input current	☐	Others: LED indicator
☐	Timing	☐	Others: Sound
☐	Illumination	☐	Others:
Supplementary information:			

Immunity test	Monitored - Checked function(s)/parameter(s) during / after the test	Method
Electrostatic discharge	PASS	Visual
Radio-frequency electromagnetic fields	PASS	Camera
Fast transients	N/A	N/A
Surge transient	N/A	N/A
Injected currents (radio-frequency common mode)	N/A	N/A
Power frequency magnetic field immunity	PASS	Visual
Voltage dips and short interruptions	N/A	N/A
Supplementary information:		

5.3 Electrostatic discharge immunity — VERDICT: PASS

Electrostatic discharges (ESD) are the result of persons or objects that accumulate static electricity due to for instance walking on synthetic carpets. The ESD can influence the operation of equipment or damage its electronics, either by a direct discharge or indirectly by coupling or radiation. Both effects are simulated during the tests.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2							
Basic standard	IEC 61000-4-2							
Port under test	Enclosure							
Air discharges	☒	±2 kV	☒	±4 kV	☒	±8 kV	☐	kV
Contact discharges	☐	±2 kV	☒	±4 kV	☐	±8 kV	☐	kV
Number of discharges	≥ 10 per polarity with ≥ 1 sec interval.							
Performance criterion	B; During the test degradation is allowed. No change of operating state or stored data is allowed. Refer to the chapter 5.1 for details.							


Performed tests


Set-up	☒	Table-top	☐	Floor standing
Ambient temperature [°C]	21		Relative Humidity air [%]	38
Voltage – Mains [V]	48 Vdc			
Frequency – Mains [Hz]	---			
Operating mode(s) used	Mode 1			


	Test Point (Location of discharge, see also photo)	Test Voltage [kV] & Polarity	Coupling type	# of applied discharges / polarity	Discharge interval [s]	Result	Test result criterion
☒	Points on conductive surface as indicated in the picture below.	±4	Contact	10	1	Pass	A
☒	Points on non-conductive surface as indicated in the picture below.	±2, ±4, ±8	Air	10	1	Pass	A
☒	HCP top side.	±4	Contact	10	1	Pass	A
☒	HCP bottom side.	±4	Contact	10	1	Pass	A
☒	VCP right side.	±4	Contact	10	1	Pass	A
☒	VCP left side.	±4	Contact	10	1	Pass	A
☒	VCP front side.	±4	Contact	10	1	Pass	A
☒	VCP rear side.	±4	Contact	10	1	Pass	A


Observation(s)	There was no change operated with initial operating during the test.
Supplementary information:	


Photo of selected test points






13
14
15
16
18
19
17
20
21


°C
高温
22



Red: Air discharge;
Blue: Contact discharge

5.4 Radio-frequency electromagnetic fields immunity — VERDICT: PASS

During the test it is verified if the equipment under test (EUT) has sufficient immunity against radiated electromagnetic fields. Industrial electromagnetic sources, walkie-talkies, radio transmitters, television transmitters and telecommunication equipment including cellular telephones and other emitting devices can generate these fields.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2				
Basic standard	IEC 61000-4-3				
Port under test	Enclosure				
Frequency range	Test level		Modulation	Dwell time	Step size
	EN IEC 61000-6-1	EN IEC 61000-6-2			
80 – 1000 MHz	3 V/m	10 V/m	80% AM (1kHz)	≥ 0,5 s	≤ 1%
1400 – 6000 MHz	3 V/m	3 V/m	80% AM (1kHz)	≥ 0,5 s	≤ 1%
Supplementary information:					

Performed tests

Test method	☒	EN 61000-4-3					
Test set-up	☒	Equipment on the table (0,8 m height)					
(see annex 2 for photo)	☐	Equipment standing on floor (0,05 – 0,15 m height)					
Voltage – Mains [V]	48 Vdc			Frequency – Mains [Hz]	---		
Operating mode(s) used	Mode 1						
Frequency range (applied)	Antenna Polarization	Test level (applied)		Modulation (applied)	Dwell time (applied)	Remark	Test result criterion
80 – 1000 MHz	H	3 V/m		80% AM (1kHz)	3 s	Pass	A
(step size 1%)	V	3 V/m		80% AM (1kHz)	3 s	Pass	A
1400 – 6000 MHz (step size 1%)	H	3 V/m		80% AM (1kHz)	3 s	Pass	A
	V	3 V/m		80% AM (1kHz)	3 s	Pass	A
Exposed side of the EUT	☒	Front (0°)	☒	Right (90°)	☐	Top	
	☒	Rear (180°)	☒	Left (270°)	☐	Bottom	
Observation(s)	There was no change operated with initial operating during the test.						
Supplementary information:							

5.5	**Electrical Fast Transients immunity**	**VERDICT:**	**N/A**

The EFT immunity test simulates disturbances by bursts of very short transients caused for example by switching off loads such as an AC motor or bouncing relay contacts. The transients are likely to disturb electronics but less likely to cause damage.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2			
Basic standard	IEC 61000-4-4			
Pulse characteristics	5/50 ns			
Port	Test level		Repetition frequency[3)]	Duration
	EN IEC 61000-6-1	EN IEC 61000-6-2		
AC input-output power ports	± 1000 V	± 2000 V	5 or 100 kHz	≥1 min. / polarity
DC input-output power ports[2)]	± 500 V	± 1000 V		
Signal/control ports [1)]	± 500 V	± 1000 V		

[1)] Only applicable to ports interfacing with cables whose total length may exceed 3 m.

[2)] Not applicable to input ports intended for connection to a battery or a rechargeable battery which must be removed or disconnected from the apparatus for recharging. Apparatus with a DC power input port intended for use with an AC–DC power adaptor shall be tested on the AC power input of the AC- DC power adaptor specified by the manufacturer or, where none is so specified, using a typical AC–DC power adaptor. The test is applicable to DC power input ports intended to be connected permanently to cables longer than 3 m.

[3)] The test may be performed at one or at both repetition frequencies. The use of 5 kHz repetition frequency is traditional; however, 100 kHz is closer to reality

Performed tests

Voltage – Mains [V]	---			
Frequency – Mains [Hz]	---			
Operating mode(s) used	---			
Test Set-up (see annex 2 for photo)	☐	Equipment standing on floor at (0,1 ± 0,01) m above ground plane		
	☐	Equipment on the table (0,1 ± 0,01) m above ground plane		
	☐	Artificial hand applied. Location refer to chapter 8.		
Coupling	☐	Common mode	☐	Other:

Port under test	Test Voltage &Polarity	Repetition Frequency	Test duration / polarity	Injection method				Remark	Test result criterion
---	---	---	---	☐	CDN	☐	Clamp	---	---
Observation(s)	---								
Supplementary information:									

5.6 **Surge transient immunity**	**VERDICT: N/A**

The surge transient immunity test simulates the surges that are caused by over-voltages due to indirect (induced) lightning transients. The pulse is a slow transient with high-energy contents and due to its long duration may cause damage to an unprotected EUT.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2				
Basic standard	IEC 61000-4-5				
Pulse characteristics	1,2/50μs Voltage; 8/20μs Current				
Repetition rate	≤ 60 secs. (for each test level and phase angle)				
Number of pulses	5 pulses (at each polarity and phase angle)				
Port	Test level & Polarity & Coupling				Phase angle [°]
	EN IEC 61000-6-1		EN IEC 61000-6-2		
	Line to Line[1)]	Line to Earth[1)]	Line to Line[1)]	Line to Earth[1)]	
AC input-output power ports	± 1 kV	± 2 kV	± 1 kV	± 2 kV	0, 90, 180, 270
DC input-output power ports [2)]	± 0.5 kV	± 1 kV	± 0.5 kV	± 1 kV	---
Signal/control ports[3)]	N/A	± 1 kV	N/A	± 1 kV	

[1)] In addition to the specified test level, all lower test levels as detailed in EN 61000-4-5 should also be satisfied.

[2)] Not applicable to input ports intended for connection to a battery or a rechargeable battery which must be removed or disconnected from the apparatus for recharging. Apparatus with a DC power input port intended for use with an AC–DC power adaptor shall be tested on the AC power input of the AC–DC power adaptor specified by the manufacturer or, where none is so specified, using a typical AC–DC power adaptor. DC ports, which are not intended to be connected to a DC distribution network are treated as signal ports.

[3)]Applicable only to ports interfacing with long distance lines.

Performed tests

Voltage – Mains [V]	---
Frequency – Mains [Hz]	---
Operating mode(s) used	---
Repetition rate	60 secs. (for each test level and phase angle)
Number of pulses	5 pulses (at each polarity and phase angle)

Port under test	Coupling	Test level & Polarity	Phase angle [°]	Remark	Test result criterion
---	---	---	---	---	---
Observation(s)	---				
Supplementary information:					

5.7	**Injected currents (RF common mode) immunity**	**VERDICT: N/A**

During this test the immunity of the equipment for induced or conducted electromagnetic fields is checked. Fields generated by radio and other transmitters cause RF voltages in long cables like the mains network. This test reproduces these induced disturbing voltages by injecting them to the EUT via the cabling.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2				
Basic standard	IEC 61000-4-6				
Frequency range	0,15 – 80 MHz				
Port	Test level, *Uo*		Modulation	Step size	Dwell time
	EN IEC 61000-6-1	EN IEC 61000-6-2			
AC input-output power	3 V	10 V	80% AM (1kHz)	≤ 1%	≥ 0,5 s
DC input-output power ports [1)]	3 V	10 V	80% AM (1kHz)	≤ 1%	≥ 0,5 s
Signal/control port [1)]	3 V	10 V	80% AM (1kHz)	≤ 1%	≥ 0,5 s
[1)] Only applicable to ports interfacing with cables whose total length, may exceed 3 m.					

Performed tests

Test method (applied)	Frequency range (applied)	Modulation (applied)	Step size (applied)
IEC 61000-4-6	0.15 – 230 MHz	80% AM (1kHz)	1%
Voltage – Mains [V]	---	Frequency – Mains [Hz]	---
Operating mode(s) used	---		

Test set-up (see annex 2 for photo)		
	☐	Equipment standing on floor at (0,1 ± 0,01) m above ground plane.
	☐	Equipment on the table (0,1 ± 0,01) m above ground plane.
	☐	Artificial hand applied. Location refer to Annex 2.

Port under test	Test Level (applied)	Injection method	Dwell time (applied)	Remark	Test result criterion
---	---	---	---	---	---

Observation(s)	---
Supplementary information:	

5.8	**Power frequency magnetic field immunity**	**VERDICT: PASS**

Magnetic fields caused by for example nearby mains frequency transformers may disturb equipment with sensitivity for these types of disturbances such as CRT monitors.

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2	
Basic standard	IEC 61000-4-8	
Port under test	Enclosure	
Field strength	EN IEC 61000-6-1	EN IEC 61000-6-2
	3 A/m	30 A/m
Test Frequency	50 Hz	
Notes: Applicable only to apparatus containing devices susceptible to magnetic fields. The test shall be carried out at the frequencies appropriate to the power supply frequency. Equipment intended for use in areas supplied only at one of these frequencies need only be tested at that frequency.		

Performed tests

Reason for not performing the test	☐	The test is not applicable as the apparatus does not contain any components susceptible to this low-frequency magnetic fields.
Voltage – Mains [V]	48 Vdc	
Frequency – Mains [Hz]	---	
Operating mode(s) used	Mode 1	
Test set-up (see annex 2 for photo)	☒	Single Coil. Dimensions: 1 m x 1 m
	☐	Single Coil. Dimensions: 2 m x 2 m
	☐	Homogeneous field (Helmholtz coil). Dimensions: 1 m x 1 m
	☐	0,1 m above metal surface

Axis under test		Tested Field strength	Test Frequency	Test Duration	Remark	Test result criterion
☒	X-axis	3 A/m	50 Hz	60 s	Pass	A
☒	Y-axis	3 A/m	50 Hz	60 s	Pass	A
☒	Z-axis	3 A/m	50 Hz	60 s	Pass	A
Observation(s)		There was no change operated with initial operating during the test.				
Supplementary information:						

5.9 Power supply interruptions and dips immunity — VERDICT: N/A

The purpose of the test is to verify the immunity of the equipment against voltage dips and voltage interruptions. It helps to ensure that the equipment functions properly (as expected and safely) with power supply fluctuations. Voltage dips and interruptions are caused by faults in the LV, MV, HV networks (short-circuit or ground faults).

Requirements

Standard	☒EN IEC 61000-6-1, ☐EN IEC 61000-6-2			
Basic standard	IEC 61000-4-11, EN 61000-4-34			
# of dips & interruptions	3 dips / interruptions for each test level and phase angle			
Interval between events	≥ 10 seconds			
EN IEC 61000-6-1				
Port under test	Test level [1]	Period (Cycles)		Performance Criterion [2]
		50 Hz	60 Hz	
AC input power port	U_{NOM} –100%	0,5	0,5	B; Refer to the chapter 5.1 for details.
	U_{NOM} – 100%	1	1	B; Refer to the chapter 5.1 for details.
	U_{NOM} – 30%	25	30	C; Refer to the chapter 5.1 for details.
	U_{NOM} –100%	250	300	C; Refer to the chapter 5.1 for details.
EN IEC 61000-6-2				
Port under test	Test level [1]	Period (Cycles)		Performance Criterion [2]
		50 Hz	60 Hz	
AC input power port	U_{NOM} –100%	1	1	B; Refer to the chapter 5.1 for details.
	U_{NOM} – 60%	10	12	C; Refer to the chapter 5.1 for details.
	U_{NOM} – 30%	25	30	C; Refer to the chapter 5.1 for details.
	U_{NOM} –100%	250	300	C; Refer to the chapter 5.1 for details.

1) Changes to the voltage level shall occur at a zero crossing point in the a.c. voltage waveform.

2) For electronic power converters, the operation of protective devices (e.g. undervoltage protection) and the performance criterion C are allowed.

NOTE: Where the equipment has a rated voltage range the following shall apply:
- If the voltage range does not exceed 20% of the lower voltage specified for the rated voltage range. A single voltage within that range may be selected for testing.
- In all other cases, the test procedure shall be applied for both the lowest and highest voltages declared in the voltage range.

Performed tests

U_{NOM} [V_{AC}]	Terminal	Test level [% U_{NOM}]	Duration [cycles]		Repetion rate [s]	Number of dips per test	Phase angle [°]	Remark	Test result criterion
			50 Hz	60 Hz					
---	---	---	---	---	---	---	---	---	---
Operating mode(s) used	---								
Observation(s)	---								
Supplementary information:									

6 IDENTIFICATION OF THE EQUIPMENT UNDER TEST

Radiated Emission / AC2

Instrument	Manufacturer	Model No.	Serial No.	Cali. Date	Cali. Due Date	Used In
EMI Test Receiver	R&S	ESCI	100726	2025.05.18	2026.05.17	☒
Bilog Antenna	Schaffner	CBL6112B	2933	2024.08.11	2025.08.10	☒
Coaxial Cable	Huber+Suhner	SUCOFLEX 106	AC2-C	2025.03.16	2026.03.15	☒
Coupling / Decoupling Network	TESEQ	CDNE M310	59297	2025.03.15	2026.03.14	☐
Attenuator	Hua Xiang	TS-2	11090504	2025.03.16	2026.03.15	☒
Temperature/Humidity Meter	RTS	RTS-1909	THM-021	2025.04.30	2026.04.29	☒
Software	Quietek	EMI_V3	V3.0.0	N/A	N/A	☒

Electrostatic discharge /TR21

Instrument	Manufacturer	Model No.	Serial No.	Cali. Date	Cali. Due Date	Used In
ESD Simulator	EM TEST	NSG 438A	237	2024.09.05	2025.09.04	☒
ESD Simulator	NoiseKen	ESS-B3011A	ESS2295199	2025.05.23	2026.05.22	☐
Barometer	Boji	DYM3	20546	2025.01.15	2026.01.14	☒
Temperature/Humidity Meter	RTS	RTS-1909	THM-015	2025.04.30	2026.04.29	☒

Radio-frequency electromagnetic field /AC4

Instrument	Manufacturer	Model No.	Serial No.	Cali. Date	Cali. Due Date	Used In
Signal Generator	R&S	SMB100A	114728	2025.03.23	2026.03.22	☒
Power Meter	R&S	NRP2	106362	2025.03.23	2026.03.22	☒
Power Sensor	R&S	NRP6A	101411	2025.03.16	2026.03.15	☒
Power Sensor	R&S	NRP6B	101412	2025.03.16	2026.03.15	☒
RF Switch	R&S	OPS120	101944	N/A	N/A	☒
Power Amplifier	R&S	BBA150 BC500	102912	N/A	N/A	☒
Power Amplifier	R&S	BBA150 D200	102889	N/A	N/A	☐
Power Amplifier	R&S	BBA150 E200	102890	N/A	N/A	☐
Power Amplifier	NTWPA	NTWPA-1060400P	23103291	2025.07.05	2026.07.04	☒
LOG Antenna	R&S	HL046E	100257	N/A	N/A	☐
Double Log-Periodic Antenna	SCHWARZBECK	STLP 9149	00817	N/A	N/A	☒
Stacked Double Log-Periodic	SCHWARZBECK	STLP 9128E	01182	N/A	N/A	☒

Radio-frequency electromagnetic field /AC4						
Instrument	**Manufacturer**	**Model No.**	**Serial No.**	**Cali. Date**	**Cali. Due Date**	**Used In**
Antenna						
Filed Probe	AR	FL7006/KIT	0349902	2025.02.14	2026.02.13	☐
Audio Analyzer	R&S	UPV	101198	2025.01.18	2026.01.17	☐
Sound Calibration	B&K	4231	3026849	2025.07.01	2026.06.30	☐
Amplifier	MegaSig	PM0043	1140304002020009	2025.05.20	2026.05.19	☐
Microphone	XH	PFMP-ABT/C35	N/A	2025.03.03	2026.03.02	☐
Temperature/Humidity Meter	RTS	RTS-1909	THM-018	2025.04.30	2026.04.29	☒
Software	R&S	EMC 32	V10.40.10	N/A	N/A	☒

Power-frequency magnetic field / TR2						
Instrument	**Manufacturer**	**Model No.**	**Serial No.**	**Cali. Date**	**Cali. Due Date**	**Used In**
Immunity Test System	EMC PARTNER	IMU-MGE	109937-1582	2025.01.18	2026.01.17	☒
Power frequency magnetic field test system	EMC PARTNER	MF1000-1	103480-1652	2025.01.11	2026.01.10	☒
Temperature/Humidity Meter	RTS	RTS-1909	THM-013	2025.04.30	2026.04.29	☒

7 ANNEX 1 - MEASUREMENT UNCERTAINTIES

The table(s) below show(s) measurement uncertainties of the EMC test set-ups. The reported expanded uncertainties are based on a standard uncertainty multiplied by a coverage factor of k=2, providing a level of confidence of approximately 95%.


Radiated emission / AC2
The maximum measurement uncertainty is evaluated as: Horizontal: 30MHz~200MHz: 4.7dB 200MHz~1000MHz: 4.4 dB Vertical: 30MHz~200MHz: 4.9 dB 200MHz~1000MHz: 4.3 dB
Electrostatic discharge immunity / TR21
The maximum measurement uncertainty is evaluated as: Rise Time: 6.4 %, Peak Current: 6.0 %, Current at 30 ns: 6.0 %, Current at 60 ns: 6.0 %.
Radio-frequency electromagnetic fields immunity / AC4
The maximum measurement uncertainty is evaluated as: 1.5 dB.
Power-frequency magnetic field immunity / TR2
The maximum measurement uncertainty is evaluated as: Current:10 %.

8 ANNEX 2 - TEST PHOTOS


Radiated emissions (30 MHz to 1000 MHz): Front View




Radiated emissions (30 MHz to 1000 MHz): Side View




Electrostatic discharge immunity




Radio-frequency electromagnetic field immunity (Below 1GHz)



Radio-frequency electromagnetic field immunity (Above 1000 MHz)



Power-frequency magnetic field



ANNEX 3 - EUT PHOTOS

EUT PHOTOS (1)



EUT PHOTOS (2)



EUT PHOTOS (3)



End of the report